

表三三五～一 液密型金屬可撓導線管管徑之選定

導線線徑		絕緣導線數								
單線 (mm)	絞線 (mm ²)	1	2	3	4	5	6	7	8	9
		導線管最小管徑 (mm)								
1.6		16	16	16	16	20	20	20	25	25
2.0	3.5	16	16	16	20	20	20	25	25	25
2.6	5.5	16	16	20	20	25	25	25	32	32
	8	16	20	20	25	25	32	32	32	32
	14	16	20	25	25	32	32	32	40	40
	22	16	25	25	32	40	40	50	50	50
	30	16	32	32	32	40	50	50	50	63
	38	20	32	32	40	50	50	50	63	63
	50	20	32	40	50	50	63	63	63	63
	60	20	40	40	50	63	63	63	63	75
	80	25	40	50	50	63	63	75	75	75
	100	25	50	50	63	63	75	75	90	90
	125	32	50	63	63	75	75	90	110	110
	150	32	63	63	75	75	90	110	110	
	200	32	63	63	75	90	110			
	250	40	75	75	90	110				
	325	50	75	90	110					
	400	50	90	90						
	500	50	110	110						

註：1. 導線一條適用於設備接地導線及直流電路。
2. 最小管徑依 CNS 規定以標稱管徑為準。